



# 防爆合格证

证号: GYJ15.1010X

由 Palmstierna International AB

制造的产品:

(地址: Korta Gatan 9, SE-171 54 Solna, Sweden)

名称 数字阀门定位器

型号规格 D3E, Logix 800si-15, D20E, APEX9000

防爆标志 Ex d II B + H<sub>2</sub> T6 Gb; Ex tD A21 IP66 T100°C

产品标准 /

图样编号

经图样及技术文件的审查和样品检验, 确认上述产品  
符合 GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、  
GB12476.5-2013 标准,

特颁发此证。

本证书有效期: 2015年1月15日至2020年1月14日

- 备注
1. 安全使用注意事项见本证书附件。
  2. 证书编号后缀“X”表明产品具有安全使用特殊条件, 内容见本证书附件。
  3. 产品具体认可型号见使用说明书。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一五年一月十五日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号  
邮编: 200233

网址: [www.nepsi.org.cn](http://www.nepsi.org.cn)  
Email: [info@nepsi.org.cn](mailto:info@nepsi.org.cn)

电话: +86 21 64368180  
传真: +86 21 64844580



# EXPLOSION PROTECTION

## CERTIFICATE OF CONFORMITY

Cert NO.GYJ15.1010X

This is to certify that the product

**Digital Positioner**

manufactured by **Palmstierna International AB**

(Address:Korta Gatan 9, SE-171 54 Solna, Sweden)

which model is **D3E, Logix 800si-15, D20E, APEX9000**

Ex marking **Ex d II B + H<sub>2</sub> T6 Gb; Ex tD A21 IP66 T100°C**

product standard /

drawing number /

has been inspected and certified by NEPSI, and that it conforms to **GB 3836.1-2010,GB 3836.2-2010,GB 12476.1-2013, GB12476.5-2013**

This Approval shall remain in force until **2020.01.14**

**Remarks** 1.Conditions for safe use are specified in the attachment to this certificate.  
2.Symbol "X" placed after the certification number denotes specific conditions of use, which are specified in the attachment to this certificate.  
3. Refer to the instruction manual for detailed models approved.

**Director**



**National Supervision and Inspection Centre for  
Explosion Protection and Safety of Instrumentation**

Issued Date **2015.01.15**

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road  
Shanghai 200233, China

<http://www.nepsi.org.cn>  
Email: [info@nepsi.org.cn](mailto:info@nepsi.org.cn)

Tel: +86 21 64368180  
Fax: +86 21 64844580